



Dennis Rubin  
Fire Chief

**KANSAS CITY KANSAS FIRE DEPARTMENT**  
**Division of Fire Prevention**

**John Droppelmann, Fire Marshal**  
**Fire Headquarters Building**  
**815 North 6th Street**  
**Kansas City, Kansas 66101**



Phone: 573-5550  
Fax: 551-0490

**2023 American Royal BBQ Competition**

- Portable fire extinguisher present (minimum one 2-A)
- Combustible materials not in tents
- Combustible vegetation and materials not within 30ft of tent
- Trash stored properly and removed daily
- Generator minimum of 20ft from tent
- Tent anchored properly
- Adequate number of exits – 2 exits (10-199) 3 exits (200-499)
- Tent is flame resistant (NFPA 701 label present on tent)\*
- 3ft clearance of all inside objects from tent walls

**The following only apply to tents with an occupancy limit over 50 persons:**

- Exits signs present
- Exit signs illuminated
- Means of egress illuminated
- Heating and cooking equipment more than 10ft from exits
- Heating and cooking equipment more than 10ft from combustibles

\*Due to late notice this year, tents do not have to be flame resistant. **Next year, tents will be required** to be flame resistant if there is a heat source underneath.

\*\*If using hay bales, a water can is highly suggested.